

## **CITY OF GUADALUPE**

DATE: September 14, 2022

PROJECT: 2022 Pavement Rehabilitation Project

**ADDENDUM NO.: 1**

BID DATE: Thursday, September 22, 2022 @ 2:00 PM

### **NOTICE TO ALL CONTRACTORS SUBMITTING BIDS AND TO ALL PLAN HOLDERS:**

You are notified of the following changes, clarifications, or modifications to the contract documents. This addendum shall supersede the original contract documents and subsequent addenda. Wherein this addendum contradicts the original contract documents and previous addenda; this addendum shall take precedence. All other conditions shall remain unchanged. The change specified below shall become a legal part of the original contract documents.

#### **A. CHANGES AND/OR CLARIFICATIONS TO THE SPECIFICATIONS:**

1. The Bid Schedule is replaced in its entirety with the attached Bid Schedule (Pages 3-12). The revised Bid Schedule corrects numbering issues.
2. Add Section TS-1.07(A) Potholing as follows:

Before initiating construction that may impact existing underground utilities, pothole the existing underground utilities and verify locations and elevations. Pothole at enough locations to assure adequate protection of the utilities during construction. Perform potholing at least ten working days in advance of the start of construction to allow for coordination with the various utility companies.

#### **B. RESPONSE TO QUESTIONS:**

1. See attached sheet.

**Contractors shall note the acknowledgment of this addendum on page 12 of the Bid Documents (Bid Schedule).**